

**PROFARMA FOR SAFE DRINKING WATER AND**  
**SANITARY CONDITION CERTIFICATE**

No.21

Dated. 07/03/2024

It is to certify that an inspection team headed by **CHANDAN PIPLAD (ASST. ENGG.)** (Name of the officers with Designation) From **MUNICIPAL CORP. BHOPAL** (Name of Department/Office) inspected the **MOUNT LITERA ZEE SCHOOL BHOPAL, Dist. Bhopal, (M.P.)** on **28/2/24** and found the **MOUNT LITERA ZEE SCHOOL BHOPAL Dist. Bhopal, (M.P.)** has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/ UT Govt.

The above is valid for a period of ONE YEAR

01/03/2024 TO 01/03/2025

Signature

(चंदन पिपलाद)  
Name:- CHANDAN PIPLAD

जलकाम विभाग जोन  
Designation :- ASST. ENGG. पाल

Name & Address of the  
office/Department BMC

To,


MOUNT LITERA ZEE SCHOOL,

BHOPAL, Dist. Bhopal, (M.P.)

Add. 340, Chann, ward no. 85,

Near Amer Majestic, Hoshangabad Road Bhopal

(Name and address of the institution)



PRINCIPAL  
Mount Litera Zee School  
Bhopal



Water Testing Laboratory 5 MGD  
Nagar Nigam, Arera Hills, Bhopal

Test Report


Nature of sample :- Water Sample		Not Collect By Nagar Nigam WTL		Unique Identification No.			
Sender's name and address TO, Mount Litera Zee School 340 Gram Chhan Near Hotel Amer Magestic H.R Bhopal		Sender's letter no.		Sender's letter Date			
		WTL Ref. No		WTL receipt date			
		Date of analysis started		28.02.2024		Date of analysis completed	
		Quantity Of sample		Ok		29.02.2024	


Sample details

No.	Particulars of sample
1.	340 Gram Chhan Near Hotel Amer Magestic H.R Bhopal (WATER SAMPLE)
2	

RESULTS

No.	Charactoristics/ Unit	tost methods	BIS -10500:2012 Reaffirmed In Sep 2022		Results			
			Desirabl Limit	Permissible Limit	1	2	3	4
1	2	3	4	5				
1	Colour in CU	IS 3025 Part 4: 2021	5	15	NIL			
2	Iron as Fe mg/l	APHA 23nd Edition,3500-fe B	1.0	1.0	0.02			
3	Nitrate as NO3 mg/l	APHA 23nd edition ,4500 NO3 -B	45	45	0.2			
4	pH pH Value at 25°C	IS 3025 Part 11: 1983	6.5 to 8.5	6.5 to 8.5	7.20			
5	Chloride as Cl mg/l	IS 3025 Part 32: 1988	250	1000	30			
6	Total Alkalinity as CaCO <sub>3</sub> mg/l	IS 3025 Part 23: 1986.	200	600	80			
7	Calcium as Ca <sup>++</sup> mg/l	IS 3025 Part 40: 1991	75	200	10			
8	Magnesium as Mg <sup>++</sup> mg/l	APHA 23 <sup>rd</sup> edition, 3500 Mg-	30	100	8.4			
9	Turbidity In NTU	IS.3025 Part 10: 2023	1.0	5.0	1.2			
10	Total hardness as CaCO <sub>3</sub> mg/l	IS 3025 PART 21: 2009	200	600	60			
11	Residual ChlorinePPM	-	0.2	1.0	-			
12	TDS By meter mg/l	IS 3025 Part 11: 1984	500	2000	122			
13	Manganese as Mg/l	Mn APHA 23nd edition 3500-mn-B	0.1	0.3	-			
14	Fecal coliform (TTC) per 100 ml	APHA 23 <sup>rd</sup> edition, 9211 B	NIL for treated wter and water in distribution system		NIL			

  
PRINCIPAL  
Mount Litera Zee School  
Bhopal

  
Quality Manager  
CHEMIST,  
5 M.G.D. W/T. PLANT  
Nagar Nigam, BHOPAL